

28/03/2019

Generalities

Modelling principles

COM / BOM

Control needs  
& typical  
structures/schemes

Now

Models of concepts  
for electrical  
thermal energy systems

Dist compensation

Cascade control

Decoupling


MTC

problems &  
solutions

case studies

E 1


Given a process with two actuators to be used in conjunction



$$A_1(s) = \frac{100}{1+5s}, \quad A_2(s) = \frac{500}{1+30s}, \quad P(s) = \frac{1}{1+200s}$$

- 1) Draw a scheme with one controller for  $y$ , two inner cascade loops (one per actuator) assuming that the output of the external controller is distributed to  $A_1$  and  $A_2$  multiplied respectively by  $\alpha$  and  $1-\alpha$  the inner loops for
- 2) Tune the three controllers so that the outer loop settling time be 10 minutes and the inner/outer loop frequency separation be 1 decade


1) Scheme:



2) I start with the outer loop, assuming that

$$\frac{C_1 A_1}{1 + C_1 A_1} = \frac{C_2 A_2}{1 + C_2 A_2} = 1$$

hence the scheme is



I want settling in 600s

$$\Rightarrow \text{dominant closed-loop TC } \frac{600}{5} = 120s$$

$$\Rightarrow \left. \begin{array}{l} \text{critical} \\ \text{crossover} \\ \text{cutoff} \end{array} \right\} \text{Frequency } \frac{1}{120} \approx 0,01 \text{ r/s}$$

5 Hence I want  
 $C P N \frac{0.01}{s}$  ✓  $\frac{wc}{s}$

$$\Rightarrow C = \frac{0.01}{s} \underbrace{\frac{1+200s}{1}}_{1/p} = 0.01 \frac{1+200s}{s} \quad \left| \begin{array}{l} \text{C loop} \\ \frac{0.01/s}{1+0.01/s} = \frac{1}{1+100s} = \frac{1}{1+s/w_c} \end{array} \right.$$

Cutoff Freq For external loop  $0.01 \text{ r/s}$

1 decade separation

$\Rightarrow$  cutoff freq for both internal loops  $0.1 \text{ r/s}$

10 times faster

6 Hence find  $A_1 C_1 = A_2 C_2 = \frac{0.1}{S}$

$$C_1 = \frac{0.1}{S} \times \frac{1455}{100} \quad \dots$$

$$C_2 = \frac{0.1}{S} \times \frac{14303}{500} \quad \dots$$

both P15



4VT

$$\text{if } V(s) = \mathcal{L}[v(t)]$$

$$\text{then } v(0) \text{ or } \lim_{t \rightarrow 0^+} v(t) = \lim_{s \rightarrow \infty} s V(s)$$

4VT

$$\text{if } V(s) = \mathcal{L}[v(t)]$$

$$\text{AND } \lim_{t \rightarrow \infty} v(t) \text{ EXISTS}$$

$$\text{then } \lim_{t \rightarrow \infty} v(t) = \lim_{s \rightarrow 0} s V(s)$$

EX

$$C(s) = k \frac{1+s}{s}$$

$$P(s) = \frac{1}{1+s}$$


$$\frac{U}{W} = \frac{C}{1+CP} = k \frac{1+s}{s} \frac{1}{1+\frac{1}{s}k}$$

$$= k \frac{1+s}{\cancel{s}} \frac{\cancel{s}}{s+k} = \frac{1+s}{1+s/k}$$

$W = \text{step}$  : initial  $U$ ?





$$9 \quad u(s^+) = \lim_{s \rightarrow \infty} \underset{\substack{\uparrow \\ \text{IVT}}}{s} \cdot \underset{\substack{\uparrow \\ \propto \text{ of} \\ \text{input}}}{\frac{1}{s}} \cdot \frac{1+s}{1+s/k} = k$$



- TYPICAL NEED: keep a variable between two bounds, and if it floats in between the two, do nothing.

We assume two actuators & explain through an air conditioning example, hence we talk about "heater" & "cooler".


1. Naive solution



<sup>12</sup> Suppose however you want  $y_0 \leq y \leq y_{+1}$

How to set the boundaries of the  
dead zone?

13 Clever solution (heat & cool)



# TIME DIVISION OUTPUT actuation

