



20/03/2019

① Feed Forward disturbance compensation





P&ID
disturb.

Model

↓ thermal conductance


$$C \dot{T} = P - G(T - T_e)$$

$$d \Rightarrow (sC + G)T = GT_e + P$$


$$T = \frac{1/G}{1 + s \frac{C}{G}} (GT_e + P)$$

$$T = \frac{1}{1 + s \frac{C}{G}} \left(T_e + \frac{1}{G} P \right)$$

4 Suppose P is the CS (in reality it is valve opening)



ALT-1



5

without π & C

$$R=1$$

$$\frac{T}{T_e} = \frac{\frac{1}{\sqrt{sC/G}}}{1 + \frac{1}{1+sC/G}} = \frac{1}{\cancel{1+sC/G}} \cdot \frac{\cancel{1+sC/G}}{2+sC/G}$$


$$= \frac{0.5}{1 + s \frac{C}{2G}}$$

complete hof

$$\frac{\varphi}{1 + \gamma R \varphi}$$

Reaction time depends on φ , but
to reset the effect of dist. must be
apparent

to compute C , set $\frac{T}{T_2} = 0$ in the presence
of compensation \Rightarrow slide 258



5 (decay time constant) in C

7

over-comp \Rightarrow slow down


under-comp \Rightarrow speed up

BUT our input is not P , it is the valve opening ϑ


$\vartheta \rightarrow P?$

$\vartheta \rightarrow \text{Flow} \rightarrow \text{Power}$
 \uparrow
pressure


9



Cascade control




Another energy-related cascade example



Dynamics seen by R: $(\alpha A_1 + (1-\alpha) A_2) P$
 $\alpha = \alpha(t)$ //


11



$$\frac{R_{A1} A_1}{1 + R_{A1} A_1} \sim \frac{R_{A2} A_2}{1 + R_{A2} A_2}$$

no TV system
any more
seen by
R


Alternative:



Open-loop
exhaustion



12 $|A_1(s)|$

$|A_2(s)|$



Gascode control is frequently used in combination with split-range or diverging-chain situation

Split-range



typical example; heat-cool