



23/05/2019

! CASE STUDY 2 : heat network




Contexts,
compared network

City-level network
↑ parts do not talk to one another




Topologies :

1) Ring :




BASICALLY



You act on this 3-way valve to provide the required power to the HE while maintaining acceptable temperatures

3



$$T_2 < T_1$$

$$\alpha m c (T_2 - T_3) = P \Rightarrow T_3 = T_2 - \frac{P}{\alpha m c}$$

$$T_4 = (1-\alpha) T_2 + \alpha \left(T_2 - \frac{P}{\alpha m c} \right) = T_2 - \frac{P}{m c}$$


but depends on P

independent of alpha

NOTE: need also to guarantee a certain T on the S side


Result:

T profile



If U_n takes more power, that is disturbing U_{n+1} and all the downstream ones

sequence (example)



⊕ Note: delay

↑
this valve
opens
⇒ more P
taken to
room 1
⇒ $T^* \downarrow$

→ this valve
has to
open as well
to keep T in
room 2

⇒ we may need
FF
compensation
⊕

6

hence (ring)


Simplest piping

⇒ Least surface exposed to terrain loss

BUT may need controllers to communicate with one another


Only used in quite small, single-authority compounds

3) Twin-pipe:



main advantage: any utilizer does not disturb those downstream (in the H path)

profile:




this T can drop to a level that would not be acceptable for any user, provided the heater can cope with restoring this

Trade-offs:


- 1) larger HE surfaces \Rightarrow increased cost & flowrate
less $\Delta T \Rightarrow$ smaller heater
- 2) increased flowrate \Rightarrow larger pump & pumping power
but need less $T \Rightarrow$ less H power
- 3) increased T @ heater outlet \Rightarrow less air
but more loss to terrain

10



Useful P depends on differences
 Lost P depends on absolute values } of T
 \Rightarrow Another point in favour of twin pipe

POWERS:



equivalent hydraulic impedance
For network

$$P_{\text{heating}} = w(h_H - h_C) = w\left(cT_H + \frac{\dot{q}_H}{\rho} - cT_C - \frac{\dot{q}_C}{\rho}\right)$$

SI
units)

$$c \sim 4000$$

$$\rho \sim 1000$$

$$\dot{q}_H \sim 3 \cdot 10^5$$

$$T_H \sim 130^\circ\text{C}$$

$$\dot{q}_C \sim 2 \cdot 10^5$$

$$T_C \sim 90^\circ\text{C}$$

(?)

≡

$$12 \quad c T_H + \left(\frac{P_H}{P} \right) - c T_C \left(- \frac{P_C}{P} \right)$$

$$4 \cdot 10^3 \cdot 1.3 \cdot 10^2 \quad \frac{3 \cdot 10^5}{10^3}$$

$$5.2 \cdot 10^5 \quad 3 \cdot 10^2$$

300 m

Same story
here

$$P_{\text{heating}} \approx 4000 \cdot 40 = 1.6 \cdot 10^5 \text{ W}$$

$$P_{\text{pump}} = w \Delta h = w \frac{p_H - p_C}{\rho} = \cancel{\rho} q \frac{p_H - p_C}{\cancel{\rho}}$$

across
the pump

$$\text{But } \frac{\Delta p}{\rho} = K w^2 = K \underset{\substack{\uparrow \\ \text{impedance}}}{q^2} \underset{\substack{\uparrow \\ \text{volume} \\ \text{flow rate}}}{\rho^2} \Rightarrow \Delta p = K \rho^3 q^2$$

$$\text{Hence } P_{\text{pump}} = \rho \Delta p = K \rho^3 q^3$$

14 Sum of

$P_{\text{heating}} \propto q \Delta T$

$P_{\text{pumping}} \propto q^3$

(+ losses to tension)

\Rightarrow optimum point

$(\Delta T, q)$

\uparrow

That's because
 ΔT depends on this

Overall, the energy management system architecture is

Ambient
conditions
&
User
requirements
(FORECAST)



determine
optimum
Thrust and
Flow rate
Set points




Flow control loop
Thrust η η
PI S



by optimisation
OR by what-if simulation



⑥ Very often one has to compute the energy consumption on a certain time span (e.g. day) based on time-varying inputs

 expected P taken by users...

The cost function is often the result not of a computation but rather of a simulation.

17 Average practice

T_{set} = simulation model

optimise for various ambient conditions: $T_{\text{amb}}, (P_{\text{set}})$

T_{ambient}
(Forecast of P_{set}) } $\xrightarrow{\text{interpolation of simulation results}}$ optimal T_{no} & w set points.

