

09/05/2019


## LOAD FLOW (197 →)

We know how to

- regulate  $f$  & Power with just measurements of  $f$  (PR1 + SEC)
- optimally distribute generation based on Forecasts of demand (TEB)

⇒ What about the load we impose to the transmission lines? E.g., overcurrents? ⇒  $LF_{\text{problem}}$


2



$$^3 Z = R + jX$$

$$Y = \frac{1}{Z} = \frac{R - jX}{R^2 + X^2}$$


G




4


Busses

topologically



5





$$\begin{aligned}
 & \downarrow y_{13}(V_3 - V_1) \\
 & \uparrow I_1 \quad y_{12}(V_2 - V_1)
 \end{aligned}$$

$$I_1 + y_{12}(V_2 - V_1) + y_{13}(V_3 - V_1) = 0$$

$$I_2 + y_{12}(V_1 - V_2) + y_{23}(V_3 - V_2) = 0$$

$$I_3 + y_{13}(V_1 - V_3) + y_{23}(V_2 - V_3) + y_{34}(V_4 - V_3) = 0$$

$$I_4 + y_{34}(V_3 - V_4) + y_{44}V_4 = 0$$

7

