


16/05/2019




## <sup>2</sup> Air renovation

double effect

Fan

OUT  
 $T_o$



IN

$T_i$

Hyp: two flows equal

Power

$c T_o w$  —————>

←—————  $c T_i w$

3 net power (In to Out)


$$P_{io} = \underbrace{WC}_{\text{equivalent conductance}} (T_i - T_o)$$

equivalent conductance  
depending on flowrate


## Modelling of controlled machines

Most machines (heaters, air conditioners, chillers, AHUs etc...) come with controls aboard.

example



5 We do not want to model the internal physics



Back to AHU example

$$T_{\text{control ON}}: T_{\text{out}} + \gamma_{\text{TC}} \dot{T}_{\text{out}} = T_{\text{out SP}} \quad T_{\text{out SP}} \rightarrow \boxed{\frac{1}{1+s\gamma}} \rightarrow T_{\text{out}}$$

$$T_{\text{control OFF}}: T_{\text{out}} + \gamma_{\text{TF}} \dot{T}_{\text{out}} = T_{\text{IN}}$$

$$W_{\text{control ON}}: W + \gamma_{\text{WC}} \dot{W} = W_{\text{SP}}$$

$$W_{\text{control OFF}}: W + \gamma_{\text{WF}} \dot{W} = 0$$


$\gamma_{\text{TC}}$ : TC of  $T$  control, closed loop

$\gamma_{\text{TF}}$ : " For Free motion of  $T_{\text{out}}$  toward  $T_{\text{IN}}$

What about consumption?

For:  $W_{\text{fan}} = \text{vol Flow rate} \cdot \Delta p = \frac{w}{\rho} \Delta p$

parameter OR  $\propto w^2$   $\Rightarrow \propto \left(\frac{w}{\rho}\right)^3$



8 Heating:

we control  $T_{out}$

$T_{in}$  depends on the rest of the model


We also control  $\dot{W}$

$$\dot{Q}_{heat} = C \dot{W} (T_{out} - T_{in})$$

↓  
Then the real consumptions may be obtained by dividing by some efficiencies


Are we incurring in some error? Yes, but only transiently

EXAMPLE



Note: in general air renovation implies some heat recovery


Example (winter, heating)



Note 2: some mixing can occur to  
lighten the burden on AHUs

EX (conditioning)

OUTSIDE  
HOT, HUMID



12 FF compensation of outside T for control of internal T

