


18/06/2014

1




Many different configurations exist

Note: unreviewed material

Typical model & control structure

(1)

Heat exchanger:
Flow and outlet T
control are here
identical




k Friction-related coefficient
 L piping lengths
 $w_i \ll w$


statically

$$w_i c (T_{1h} - T_{1c}) = P_1$$

3




If we want a dynamic model, we associate each primary side of a HE to one (or more) capacity, thus



4 Control at the user level

We want a certain P_i (required by the utilizers)

We have limits on the return temperature
and on the taken flow rate




The hot side temperatures do not depend on the loads of the upstream users (but the available flows do)

So, a too low cold T may be a problem for the central heater

while a too high w_i can be a problem for downstream users
→ CONFLICTING NEEDS


Typical layout (one of many...)



Alternatively, treat the secondary exchanger side as a local heater and just control w and T_{sh} .

Or, immediately, control w and $T_{sh} - T_{sc}$

Primary side



Two needs (not exceeding
boundaries on w_i and T_{ic})
One manipulated variable

Reasoning: suppose T_{ih} unpressed, and P_i as well (sec control)

$$\Rightarrow (\underline{T_{ih}} - T_{ic}) \cdot w_i = \underline{P_i} \quad T_{ih} - T_{ic} = \frac{P_i}{c w_i}$$

$$T_{ic} = \underline{T_{ih}} - \frac{P_i}{c w_i}, \text{ so } w_i \uparrow \Rightarrow T_{ic} \uparrow$$

$\Rightarrow W_i \uparrow \Rightarrow T_{ic} \uparrow$

} have a lower limit on T_{ic} and an upper one on W_i

\Rightarrow as lag as T_{ic} is high enough, take the minimum W_i compatible with the sizing of the HE

- if we approach the lower bound for T_{ic} , increase W_i

\Rightarrow (1) two controllers, higher ^{value opening} repeat unit (other tracks)

(2) (simpler) : just control W_i , schedule the set point based on T_{ic}

As for controllers, PI ones suffice


Heater side control

W control \rightarrow PI loop acting on pump(s)

Only issue: be cautious with response speed requirements as the network fluid has a huge inertia

Outlet T control \rightarrow PI loop (possibly with TID action) on the Fuel valve, or equivalent.

Only relevant problem: generating the temperature set point
 Principles and modes operation



PIPING
 SECTION
 $H \gg d$

$$\text{losses} = f(T_{ho}, T_{hco}, T_{hu}, T_{hu})$$

hot Temps \Rightarrow hot pipe losses and w_i
 cold Temps \Rightarrow cold pipe losses, w_i
 and \dot{Q}_i

1 Drawing up,

T_{ho}
 w
 w_i
 P_i

} $\rightarrow T_{return}, T_{ih}, T_{ic} \Rightarrow$ worst-case (lowest)

T_{return} under the
hypothesis that the best
 T_{ih} is high enough

\Rightarrow losses

Set the set point for T_{ho} to the lowest value fulfilling
the worst case analysis (plus a few degrees) \Rightarrow min loss

Of course one can have different The set points
for different situations (e.g., loads may not be the
same for day & night, or working days vs holidays, and
so on).

⇒ Relevant research/engineering issue: exploiting
heat storages.
