



16/06/2014




B Actuation scheme

Note: unreviewed material

2




38.



Solution: quantise the control signal





Possibility 1: quantise in the whole range



Possibility 2: quantise just at the extrema (\Rightarrow IV sat)

① can cause limit cycles (permanent oscillations)
more likely than 2

5




$$U \rightarrow \begin{bmatrix} S_R \\ S_I \end{bmatrix} \rightarrow \begin{matrix} U_I(\omega) \\ U_I(\omega) \end{matrix}$$



CASE STUDY 2


Heat network (simple layout)



OBJECTIVE

Fulfil demand (power) requirements $P_1 \dots P_n$
while keeping T_n high enough


• Remark



$$P_i = w c (T_{hi} - T_{ho})$$

to fulfil P_i we
adjust the T drop

Remember, we take the load
 P_i as an exogenous
input (hand request by user)



hydrolysis
the process


$$P_{loss} = f(T_{ho}, T_{hi}, w, T_{ext})$$

e.g.

$$P_{loss} = G_{loss} \left(\frac{T_{ho} + T_{hi}}{2} - T_{ext} \right)$$

Need to keep pumping at as low T
as possible

- How users typically operate HES



For us, each load takes \geq prescribed POWER



